




Municipal Corporation of Delhi
Office of Deputy Health Officer
Najafgarh Zone



No: DHO/NGZ/MCD/2022/D- 1847

Dated 01/08/2022

1. Name of the School **ADARSH PUBLIC SCHOOL**
2. School Address **SHYAM ENCLAVE DEENPUR NAJAFGARH NEW DELHI.**
3. No. of Shift **ONE** Timing **08:00 AM TO 02:00 PM**
4. No. of Students: **Boys 179 Girls 130 Total = 309**
5. No. of Staffs: **Male 04 Female 13 Total = 17**

Details of Accommodations present in School

- | | |
|---|------------------------|
| 1. Floor Space in the Classroom Sufficient/insufficient | SUFFICIENT |
| 2. The Classrooms are Well Lighted/ ill lighted | WELL LIGHTED |
| 3. The Classrooms are Well Ventilated/ ill ventilated | WELL VENTILATED |
| 4. The Classrooms are kept / Not kept Neat & Clean: | NEAT AND CLEAN |
| 5. The Building requires/does not required Whitewash etc. | NOT REQUIRED |
| 6. The Drinking Water is Wholesome/ not wholesome | WHOLESOME |
| 7. The Latrine arrangement is Sanitary/ insanitary | SANITARY FROM |
- HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard

Deputy Health Officer

Najafgarh Zone

Deputy Health Officer

Najafgarh Zone MCD

(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)